

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results
WHS 96	11/14/2024 10:10	11/26/2024 12:03	70322809001	Lead	1.6
WHS 143 D-16 RT	11/14/2024 10:18	11/26/2024 12:08	70322809002	Lead	5.9
WHS 41 D-19	11/14/2024 10:22	11/26/2024 12:09	70322809003	Lead	5.5
WHS 39 D-26	11/14/2024 10:24	11/26/2024 12:11	70322809004	Lead	5.1
WHS 38 D-21	11/14/2024 10:26	11/26/2024 12:12	70322809005	Lead	1.1
WHS 35 D-28	11/14/2024 10:28	11/26/2024 12:14	70322809006	Lead	5.0
WHS 31 C-2	11/14/2024 10:31	11/26/2024 12:15	70322809007	Lead	38.4
MUSIC WING BOTTLE FILL	11/14/2024 10:34	11/26/2024 12:17	70322809008	Lead	18.1
WHS 20 C-6	11/14/2024 10:36	11/26/2024 12:19	70322809009	Lead	8.5
WES 127	11/14/2024 11:35	11/26/2024 12:20	70322809010	Lead	1.8
BOTTLE FILL CAF HALL	11/14/2024 11:12	11/26/2024 12:22	70322809011	Lead	9.4
WES 114 RM 68	11/14/2024 11:13	11/26/2024 12:26	70322809012	Lead	3.2
WES 91 RM 51	11/14/2024 11:20	11/26/2024 12:28	70322809013	Lead	<1.0
WES 70 RM 46	11/14/2024 11:16	11/26/2024 12:29	70322809014	Lead	4.9
WES 67 RM 58	11/14/2024 11:17	11/26/2024 12:31	70322809015	Lead	9.9
WES 48 RM 39	11/14/2024 11:26	11/26/2024 12:33	70322809016	Lead	22.1

NYSDOH Action Level for Lead In Schools of 5 ppb