

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results
WHS 1	9/11/2024 07:10	9/23/2024 11:06	70313670001	Lead	2.1
WHS 20	9/11/2024 07:12	9/23/2024 11:07	70313670002	Lead	5.8
WHS 25	9/11/2024 07:29	9/23/2024 11:09	70313670003	Lead	1.4
WHS 31	9/11/2024 07:31	9/23/2024 11:10	70313670004	Lead	34.2
WHS 35	9/11/2024 07:20	9/23/2024 11:12	70313670005	Lead	12.4
WHS 38	9/11/2024 07:21	9/23/2024 11:14	70313670006	Lead	20.0
WHS 39	9/11/2024 07:22	9/23/2024 11:15	70313670007	Lead	13.8
WHS 40	9/11/2024 07:23	9/23/2024 11:17	70313670008	Lead	3.7
WHS 41	9/11/2024 07:24	9/23/2024 11:18	70313670009	Lead	28.1
WHS 94	9/11/2024 07:06	9/23/2024 11:23	70313670010	Lead	1.2
WHS 96	9/11/2024 07:05	9/23/2024 11:25	70313670011	Lead	5.5
WHS 109	9/11/2024 07:14	9/23/2024 11:27	70313670012	Lead	4.5
WHS 112	9/11/2024 07:09	9/23/2024 11:28	70313670013	Lead	2.5
WHS 113	9/11/2024 07:07	9/23/2024 11:30	70313670014	Lead	34.3
WHS 143	9/11/2024 07:26	9/23/2024 11:32	70313670015	Lead	21.1
CONSESSION STAND	9/11/2024 07:40	9/23/2024 11:33	70313670016	Lead	1.1
WES 1	9/11/2024 06:54	9/23/2024 11:35	70313670017	Lead	1.9
WES 7	9/11/2024 06:53	9/23/2024 11:43	70313670018	Lead	1.6
WES 8	9/11/2024 06:52	9/23/2024 11:54	70313670019	Lead	3.8
WES 9	9/11/2024 06:51	9/23/2024 11:55	70313670020	Lead	2.2
WES 10	9/11/2024 06:50	9/23/2024 11:59	70313670021	Lead	4.2
WES 11	9/11/2024 06:46	9/23/2024 12:03	70313670022	Lead	2.7
WES 12	9/11/2024 06:45	9/23/2024 12:06	70313670023	Lead	1.9
WES 26	9/11/2024 06:44	9/23/2024 12:08	70313670024	Lead	2.4
WES 28	9/11/2024 06:41	9/23/2024 12:10	70313670025	Lead	2.3
WES 30	9/11/2024 06:40	9/23/2024 12:13	70313670026	Lead	3.2
WES 32	9/11/2024 06:42	9/23/2024 12:15	70313670027	Lead	3.5
WES 35	9/11/2024 06:37	9/23/2024 12:18	70313670028	Lead	3.9
WES 44	9/11/2024 06:34	9/23/2024 12:23	70313670029	Lead	3.7
WES 47	9/11/2024 06:36	9/23/2024 12:24	70313670030	Lead	1.3
WES 48	9/11/2024 06:33	9/23/2024 12:27	70313670031	Lead	41.8
WES 50	9/11/2024 06:32	9/23/2024 12:32	70313670032	Lead	1.7
WES 67	9/11/2024 06:13	9/23/2024 12:37	70313670033	Lead	40.1
WES 70	9/11/2024 06:14	9/23/2024 12:47	70313670034	Lead	7.1
WES 82	9/11/2024 06:21	9/23/2024 12:50	70313670035	Lead	1.8
WES 88	9/11/2024 06:26	9/23/2024 12:52	70313670036	Lead	2.0
WES 91	9/11/2024 06:20	9/23/2024 12:53	70313670037	Lead	9.6
WES 97	9/11/2024 06:25	9/23/2024 12:55	70313670038	Lead	1.4
WES 100	9/11/2024 06:24	9/23/2024 13:01	70313670039	Lead	1.4
WES 103	9/11/2024 06:22	9/23/2024 13:03	70313670040	Lead	3.4
WES 109	9/11/2024 06:12	9/23/2024 13:08	70313670041	Lead	3.2
WES 114	9/11/2024 06:11	9/23/2024 13:11	70313670042	Lead	9.0
WES 117	9/11/2024 06:10	9/20/2024 14:59	70313670043	Lead	3.4
WES 127	9/11/2024 06:04	9/20/2024 15:00	70313670044	Lead	19.4
WES 133	9/11/2024 06:30	9/23/2024 13:15	70313670045	Lead	3.4

NYSDOH Action Level for Lead In Schools of 5 ppb